DEKR.

DEK!

TEST CERTIFICATE

Issued to: Elsteel (Pvt) Ltd.

Spur Road 2 Phase 1, KEPZ Katunayake - 11420

Sri Lanka

For the product: Low-voltage switchgear and controlgear assembly

Trade name: ELSTEEL

Type/Model: Techno Module Enclosure System

Ratings: IP55, IP44, IP43, IP41, IP40, IP34, IP30, IP20

IK10, IK08

For more details see annex

Manufactured by: Elsteel (Pvt) Ltd.

Spur Road 2 Phase 1, KEPZ Katunayake - 11420

Sri Lanka

Subject: Design verification

Requirements: //IEC 61439-2:2011

Clauses 10.2,6, 10.3

Remarks:

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2232505.01-INC, dated 12 July 2019.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 12 July 2019 Number: 2232505.100

DEKRA Certification B.V.

F.S. Strikwerda Certification Manager

© Integral publication of this certificate and adjoining reports is allowed